

IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEX Scheme visit www.iecex.com

Certificate No.: IECEX INE 14.0072X Issue No: 0 Certificate history:
Status: Current Page 1 of 3 Issue No. 0 (2015-02-18)
Date of Issue: 2015-02-18
Applicant: QUASAR SERVICE S.r.l.
Via Bergamo, 14
I-24050 Grassobbio (BG)
Italy
Electrical Apparatus: Pressurized Cabinets type QPS .../..
Optional accessory:
Type of Protection: ia pzc [ia/ib]
Marking: Ex ia pzc [ia Ga or ib Gb] IIB or IIB+H2 or IIC T6 or T5 or T4 or T3 Gc
Ex ia pzc [ia Da or ib Db] IIIA or IIIB or IIIC T85°C or T100°C or T135°C or T200°C Dc

Approved for issue on behalf of the IECEX
Certification Body:

Thierry HOUËIX

Position:

Ex Certification Officer

Signature:
(for printed version)

Date:

2015-02-18




1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEX Website.

Certificate issued by:

INERIS
Institut National de l'Environnement Industriel
et des Risques
BP n2
Parc Technologique ALATA
F-60550 Verneuil-En-Halatte
France

INERIS is accredited by COFRAC under number 5-0045 for certification of products and services (scope of accreditation is available on COFRAC website www.cofrac.fr)

The certification rules are available on the INERIS website www.ineris.fr.



IECEX Certificate of Conformity

Certificate No: IECEX INE 14.0072X

Issue No: 0

Date of Issue: 2015-02-18

Page 2 of 3

Manufacturer: **QUASAR SERVICE S.r.l.**
Via Bergamo, 14
I-24050 Grassobbio (BG)
Italy

Additional Manufacturing
location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition:6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-11 : 2011 Edition:6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
IEC 60079-2 : 2014-07 Edition:6	Explosive atmospheres - Part 2: Equipment protection by pressurized enclosure "p"
IEC 60079-25 : 2010-02 Edition:2.0	Explosive atmospheres – Part 25: Intrinsically safe electrical systems

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

TEST & ASSESSMENT REPORTS:


A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

FR/INE/ExTR15.0005/00

Quality Assessment Report:

FR/INE/QAR14.0004/00



IECEx Certificate of Conformity

Certificate No: IECEx INE 14.0072X

Issue No: 0

Date of Issue: 2015-02-18

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

Electrical control cabinets protected by pressurization. Pressurization control unit contains a flameproof enclosure with separated IECEx equipment certificate (IIB or IIB+H2 or IIC and IIIA or IIIB or IIIC) fitted with intrinsically safe elements when located in hazardous area, permitting pressurization by leakage compensation.

The cabinet contains a set of equipment specified by descriptive documents, in particular one or more certified electrical equipment.

CONDITIONS OF CERTIFICATION: YES as shown below:

- User shall take all convenient precautions before using by-pass system eventually included in the pressurisation control unit.
- User shall connect, on intrinsic safety terminal strip, only elements with electrical characteristics lower or equal to the characteristics defined in any certificates of associated intrinsically safe apparatus.
- All electrical elements associated with this equipment and contributing to his convenient use and safety, when located in hazardous area, must be protected by one or more standardized types of protection, certified and suitable for considered using.

Annex:

[IECEx INE 14.0072X-00_Annex.pdf](#)



IECEx Certificate of Conformity

Certificate No.: IECEx INE 14.0072X

Issue No.: 0

Page 1 of 3

Annex: IECEx INE 14.0072X-00_Annex.pdf

RATINGS

Maximum supply voltage : 11 000 V
 Maximum power : 10 000 kW
 Maximum current : 10 000 A
 Frequency : 48 to 62 Hz
 Protective gas : Air or Nitrogen

PARAMETERS RELATING TO THE SAFETY

	QPS 007	QPS 015	QPS 023	QPS 030	QPS 045	QPS 060
Free internal volume	0.05 m ³	0.1 m ³	0.15 m ³	0.2 m ³	0.3 m ³	0.42 m ³
Minimum purging flow rate ^{1/2}	7 Nm ³ /h	9 Nm ³ /h	13.8 Nm ³ /h	16 Nm ³ /h	18 Nm ³ /h	20 Nm ³ /h
Minimum purging duration ¹	3 min	5 min	5 min	6 min	7.5 min	9 min
Minimum overpressure ³	1 mbar	1 mbar	1 mbar	1 mbar	1 mbar	1 mbar
Maximum overpressure ³	5 mbar	5 mbar	5 mbar	5 mbar	5 mbar	5 mbar
Maximum leakage rate ³	2 Nm ³ /h	2 Nm ³ /h	2 Nm ³ /h	2 Nm ³ /h	3 Nm ³ /h	3 Nm ³ /h
Control point of overpressure	Valve					

	QPS 075	QPS 090	QPS 105	QPS 120	QPS 132	QPS 160
Free internal volume	0.5 m ³	0.65 m ³	0.7 m ³	0.8 m ³	1 m ³	1.2 m ³
Minimum purging flow rate ^{1/2}	22.5 Nm ³ /h	23 Nm ³ /h	26.5 Nm ³ /h	24 Nm ³ /h	26 Nm ³ /h	32 Nm ³ /h
Minimum purging duration ¹	10 min	12 min	12 min	15 min	15 min	15 min
Minimum overpressure ³	1 mbar	1 mbar	1 mbar	1 mbar	1 mbar	1 mbar
Maximum overpressure ³	5 mbar	5 mbar	5 mbar	5 mbar	5 mbar	5 mbar
Maximum leakage rate ³	3 Nm ³ /h	3 Nm ³ /h	4 Nm ³ /h	4 Nm ³ /h	4 Nm ³ /h	5 Nm ³ /h
Control point of overpressure	Valve					



IECEX Certificate of Conformity

Certificate No.: IECEX INE 14.0072X

Issue No.: 0

Page 2 of 3

Annex: IECEX INE 14.0072X-00_Annex.pdf

	QPS 190	QPS 215	QPS 240	QPS 290	QPS 340
Free internal volume	1.4 m ³	1.55 m ³	1.7 m ³	2.1 m ³	2,5 m ³
Minimum purging flow rate ^{1/2}	31.5 Nm ³ /h	34 Nm ³ /h	36 Nm ³ /h	35 Nm ³ /h	34 Nm ³ /h
Minimum purging duration ¹	18 min	18 min	19 min	25 min	30 min
Minimum overpressure ³	1 mbar	1 mbar	1 mbar	1 mbar	1 mbar
Maximum overpressure ³	5 mbar	5 mbar	5 mbar	5 mbar	5 mbar
Maximum leakage rate ³	5 Nm ³ /h	5 Nm ³ /h	5 Nm ³ /h	6 Nm ³ /h	8 Nm ³ /h
Control point of overpressure	Valve				

- (1) Not required for dust marking
- (2) Measured at the inlet
- (3) During normal operation (service)

ROUTINE EXAMINATIONS AND TESTS

Each piece of equipment defined above, must have undergone successfully prior to delivery:

- According to clause 17.1 of the IEC 60079-2 standard, a verification of the performance of safety devices.
- According to clause 17.2 of the IEC 60079-2 standard, a leakage test has to be done to check the maximum leakage rate.

MARKING :

Marking has to be readable and indelible; it has to include the following indications:

- QUASAR SERVICE S.r.l
I - 24050 GRASSOBBIO (BG)
- QPS .../.¹
- IECEX INE 14.0072X
- (Serial number)
- Ex ia pzc [i* G**] II**** T***** Gc
- Ex ia pzc [i* D***] III***** T***** Dc
- Tamb = -40°C to +50°C for T6/T85°C and T5/T100°C
-40°C to +60°C for T4/T135°C and T3/T200°C
- WARNINGS: PRESSURIZED ENCLOSURE

DO NOT OPEN WHEN AN EXPLOSIVE ATMOSPHERE MAY BE PRESENT



IECEx Certificate of Conformity

Certificate No.: IECEX INE 14.0072X

Issue No.: 0

Page 3 of 3

Annex: IECEX INE 14.0072X-00_Annex.pdf

- **WARNINGS: THIS ENCLOSURE CONTAINS INERT GAS AND MAY BE AN ASPHYXIATION HAZARD (if inert gas)**
POWER SHALL NOT BE RESTORED AFTER THE ENCLOSURE HAS BEEN OPENED UNTIL COMBUSTIBLE DUST ACCUMULATIONS WITHIN THE ENCLOSURE HAVE BEEN REMOVED

¹: In accordance with the Identification code and tables of specifications which are defined in the manufacturers documents.

(*) : ia or ib

(**) : Ga or Gb

(***) : Da or Db

(****) : IIB or IIB+H2 or IIC

(*****) : IIIA or IIIB or IIIC

(*****) : T6 or T5 or T4 or T3

(*****) : T85°C or T100°C or T135°C or T200°C